



Postal Address:
 Suite 2002a, Level 20
 44 Market Street
 Sydney, New South Wales 2000
 Australia

Testing. Advising. Assuring.

EWFA CERTIFICATE OF ASSESSMENT	CERTIFICATE No : SFC 38259000	Page 1 of 1
---------------------------------------	--------------------------------------	--------------------

Report Sponsor	Certificate Issue Date	Product Name
NASAHI Building Materials Australia P/L 1331 Stud Road Rowville, VIC 3178 Australia	10/11/2015	NASAHI Super50 AAC panel

Introduction

The element of construction described below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report(s) or Regulatory Information Reports for more information.

Referenced Report	Report Date	Validity Date	Referenced Test Standard
EWFA 38259000	10/11/2015	30/11/2020	AS1530.4-2005

Summary of Assessed Performance

The fire resistance performance of NASAHI Super50 AAC external wall systems if tested in accordance with AS1530.4-2005:

Exposed Side Cladding	Batten	Wall Framing	Unexposed Side Cladding	FRL	Imposed Fire Design Load (AS1170.0 Clause 4.2.4)
Min. 50mm thick NASAHI Super50 panel	Steel batten	Min. 70mm deep timber stud	10mm thick or greater standard grade plasterboard	120/120/120	4.94kN/stud
	Timber batten			90/90/90	
	No Batten	Min. 90mm deep timber stud		90/90/90	

For a complete description of the assessed construction, refer to referenced assessment report.

Notes

THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.

Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd	
Address	Suite 2002a, Level 20, 44 Market Street, Sydney NSW 2000, Australia	
Phone / Fax	+61 (0)2 8270 7600/ +60 (0)2 9299 6076	
ABN	81 050 241 524	
Email / Home Page	www.exova.com	
Authorisation	Prepared By: S. Hu	Reviewed By: K. G. Nicholls