



This checklist is to be read in conjunction with all Nasahi documentation including the relevant Design and Installation Guide, Safe Work Method Statements (SWMS) and engineering advice from Nasahi. Coordination and compliance with specifications by the project engineers (acoustic, fire, thermal and structural), and architect is also compulsory. These project consultants are responsible for incorporating this system into the subject project. These documents are available from the Nasahi website and should be completed prior to commencement of the job.

Project Information:		
Project		
Builder:		
Installer:		
Floor Levels:		
Panel Area (m²):		
Prior to commencing installation	Complete	Action Required
Documentation and delivery		
Have all installation documents been supplied and read?		
Have the correct Nasahi Panels been delivered? (Thickness and qty)		
Have all the components been supplied? (Fixings, Nasahi Adhesive)		
Are the Nasahi Panels free of major damage?		
Frame and Slab		
Have the floor joists been completed?		
Are the dimensions and tolerances of the joists in compliance with the Installation Guide?		
Panel		
Carry panels on edge to prevent deflection and breakage		
Optimal panel layout checked and planned?		
Cut panels on flat surface to prevent corner breakage		
Panels trimmed and packed?		
All exposed steel reinforcing mesh coated with Nasahi anti-corrosion touch up paint?		
Adhesive mixed to a smooth creamy consistency?		
Are panel joints continuously sealed with Nasahi Adhesive?		
All rows of panels are installed level and plumb?		
Have the correct 14G fixings been used in accordance with the Installation Guide?		
Have control joints been installed at all joist orientation changes, eccentrically loaded locations, and where panel joints are located over bearers?		
Has back blocking been installed as all locations where panels join off a joist, and for penetrations larger than 80mm in accordance with the Installation Guide?		
Have penetrations been cut and sealed in accordance with the Installation Guide?		
Has a compliant fire rated ceiling system been installed (where specified)?		
Has fire/acoustic rated sealant been applied correctly where required?		
Have the correct insulation and lining materials been installed according to the project specification?		

Nasahi will only guarantee systems installed in accordance with relevant design and installation guide. This document is not an installation compliance certificate. An installation compliance certificate is available from our website and must be completed and submitted to Nasahi for the system to be warranted.

