



Postal Address:  
 Suite 2002a, Level 20  
 44 Market Street  
 Sydney, New South Wales 2000  
 Australia

Testing. Advising. Assuring.

<b>EWFA CERTIFICATE OF ASSESSMENT</b>	<b>CERTIFICATE No : SFC 39410000.2</b>	<b>Page 1 of 1</b>
---------------------------------------	--	--------------------

Report Sponsor	Certificate Issue Date	Product Name
NASAHI Building Materials Australia P/L 1331 Stud Road Rowville, VIC 3178 Australia	01/07/2016	NASAHI Super50 AAC panel

**Introduction**

The element of construction described below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report(s) or Regulatory Information Reports for more information.

Referenced Report	Report Date	Validity Date	Referenced Test Standard
EWFA 39410000.2	01/07/2016	30/06/2021	AS1530.4-2014

**Summary of Assessed Performance**

The fire resistance performance of NASAHI Super50 party wall systems if tested in accordance with AS1530.4-2014:

Central Membrane	Wall Framing	Max. Wall Height	Max. Vertical Space of Aluminium Bracket	Max. Horizontal Space of Aluminium Bracket	FRL
50mm Nasahi Super50 panel	Min. 70mm deep timber or steel framing	15m	3m	900mm	60/60/60
		6.6m	3m	400mm	90/90/90
		10m	3m	250mm	90/90/90
	Min. 70mm deep timber or min. 51mm deep steel framing	3m	3m	600mm	-/120/90

For a complete description of the assessed construction, refer to referenced assessment report.

**Notes**

THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.

Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.

<b>TESTING AUTHORITY</b>	Exova Warringtonfire Aus Pty Ltd	
<b>Address</b>	Suite 2002a, Level 20, 44 Market Street, Sydney NSW 2000, Australia	
<b>Phone / Fax</b>	+61 (0)2 8270 7600/ +60 (0)2 9299 6076	
<b>ABN</b>	81 050 241 524	
<b>Email / Home Page</b>	www.exova.com	
<b>Authorisation</b>	Prepared By:  S. Hu	Reviewed By:  D. Nicholson